



**Send To: 71330**

Mr. Jeffrey Vinyard  
Crystal Springs Bottled Water  
P.O. Box 90760  
Albuquerque, NM 87199-0760

**Facility: 71331**

Crystal Springs Bottled Water, Inc.  
4446 Anaheim NE  
Albuquerque NM 87113  
United States

---

**Result PASS**

**Report Date 10-OCT-2017**

---

Customer Name Crystal Springs Bottled Water, Inc.  
Tested To USFDA CFR Title 21 Part 165.110  
Description Drinking Water  
Test Type Annual Collection  
Job Number A-00245646  
Project Number 10042712 (CLAA, MLAA)  
Project Manager Anna Ciechanowski

---

**Thank you for having your product tested by NSF International.**

Please contact your Project Manager if you have any questions or concerns pertaining to this report.

**Report Authorization** *Kerri S. LeVanseler*  
Kerri Levanseler - Director, Chemistry Laboratory

**Date** 10-OCT-2017



**General Information**

Standard: USFDA CFR Title 21 Part 165.110  
Lot Number: 09-14-2017  
Product Description: Drinking Water

Sample Id: **S-0001418632**  
Description: Drinking Water - 09-14-2017  
Sampled Date: 09/20/2017  
Received Date: 09/18/2017

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
<b>Physical Quality</b>					
Alkalinity as CaCO3	5	ND		mg/LCaCO3	
Color	5	ND	15	Color Unit	Pass
Specific Conductance	10	ND		umhos/cm	
Corrosivity	0	-4.47			
Hardness, Total	2	ND		mg/LCaCO3	
Solids Total Dissolved	5	ND	500	mg/L	Pass
Turbidity	0.1	ND	5	NTU	Pass
pH	0.01	7.99			
Temperature	0	22		deg. C	
Bicarbonate	5	ND		mg/L HCO3	
Odor, Threshold	1	1	3	TON	Pass
<b>Microbiological Quality</b>					
Coliform in Water/100 mL		Absent			Pass
E. Coli in Water/100 mL		Absent			Pass
<b>Disinfection Residuals/Disinfection By-Products</b>					
Bromate	5	ND	10	ug/L	Pass
Monochloramine	0.05	ND		mg/L	
Dichloramine	0.05	ND		mg/L	
Nitrogen trichloride	0.05	ND		mg/L	
Chloramine, Total	0.05	ND	4	mg/L	Pass
Chlorite	10	ND	1000	ug/L	Pass
Chlorine Dioxide	0.1	ND	0.8	mg/L	Pass
Monochloroacetic Acid	2	ND		ug/L	
Monobromoacetic Acid	1	ND		ug/L	
Dichloroacetic Acid	1	ND		ug/L	
Bromochloroacetic Acid	1	ND		ug/L	
Trichloroacetic Acid	1	ND		ug/L	
Dibromoacetic Acid	1	ND		ug/L	
Total Haloacetic Acid	1	ND	60	ug/L	Pass
Chlorine, Total Residual	0.05	ND	4	mg/L	Pass
<b>Radiologicals</b>					
Uranium	0.001	ND	0.03	mg/L	Pass
P1 Gross Alpha	3	ND	15	pCi/L	Pass
P1 Gross Beta	4	ND	50	pCi/L	Pass
Alpha Variance +/-		2		pCi/L	
Beta Variance +/-		2		pCi/L	
Radium-226	1	ND		pCi/L	
Radium-228	1	ND		pCi/L	
Radium-226, Radium-228 Combined	1	ND	5	pCi/L	Pass
Radium 226 Variance +/-		0.2		pCi/L	



Sample Id: S-0001418632

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
<b>Radiologicals</b>					
Radium 228 Variance +/-		0.2		pCi/L	
<b>Inorganic Chemicals</b>					
Aluminum	0.01	ND	0.2	mg/L	Pass
Antimony	0.0002	ND	0.006	mg/L	Pass
Arsenic	0.001	ND	0.01	mg/L	Pass
Barium	0.001	ND	2	mg/L	Pass
Beryllium	0.0002	ND	0.004	mg/L	Pass
Bromide	10	ND		ug/L	
Cadmium	0.0002	ND	0.005	mg/L	Pass
Calcium	0.02	0.06		mg/L	
Chloride	2	ND	250	mg/L	Pass
Chromium (includes Hexavalent Chromium)	0.001	ND	0.1	mg/L	Pass
Copper	0.001	ND	1	mg/L	Pass
Cyanide, Total	0.005	ND	0.2	mg/L	Pass
Fluoride	0.1	ND	2.4	mg/L	Pass
Iron	0.02	ND	0.3	mg/L	Pass
Lead	0.0005	ND	0.005	mg/L	Pass
Magnesium	0.02	ND		mg/L	
Manganese	0.001	ND	0.05	mg/L	Pass
Mercury	0.0002	ND	0.002	mg/L	Pass
Nickel	0.005	ND	0.1	mg/L	Pass
Nitrogen, Nitrate	0.01	0.02	10	mg/L N	Pass
Nitrogen, Nitrite	0.004	ND	1	mg/L N	Pass
Total Nitrate + Nitrite-Nitrogen	0.02	0.02	10	mg/L	Pass
Potassium	0.5	ND		mg/L	
Selenium	0.001	ND	0.05	mg/L	Pass
Silver	0.001	ND	0.1	mg/L	Pass
Sodium	0.2	1.4		mg/L	
Sulfate as SO4	0.5	ND	250	mg/L	Pass
MBAS, calc. as LAS Mol.Wt. 320	0.2	ND		mg/L	
Thallium	0.0002	ND	0.002	mg/L	Pass
Phenolics	0.001	ND	0.001	mg/L	Pass
Zinc	0.01	ND	5	mg/L	Pass
<b>Organic Chemicals</b>					
Diquat (Ref: EPA 549.2)					
Diquat	0.4	ND	20	ug/L	Pass
Endothall (Ref. EPA 548.1) - (ug/L)					
Endothall	9	ND	100	ug/L	Pass
Glyphosate (Ref: EPA 547)					
Glyphosate	6	ND	700	ug/L	Pass
2,3,7,8-TCDD (Ref: EPA 1613B)					
2,3,7,8-Tetrachlorodibenzo-p-dioxin	5	ND	30	pg/L	Pass
Carbamate Pesticides (Ref: 531.2)					
Aldicarb sulfoxide	0.5	ND		ug/L	
Aldicarb sulfone	0.5	ND		ug/L	
Oxamyl	0.5	ND	200	ug/L	Pass
Aldicarb	0.5	ND		ug/L	
Carbofuran	0.5	ND	40	ug/L	Pass
Methomyl	0.5	ND		ug/L	



Sample Id: S-0001418632

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
<b>Organic Chemicals</b>					
Carbaryl	0.5	ND		ug/L	
3-Hydroxycarbofuran	0.5	ND		ug/L	
Herbicides (Ref: EPA 515.3)					
Dalapon	1	ND	200	ug/L	Pass
Dicamba	0.1	ND		ug/L	
2,4-D	0.1	ND	70	ug/L	Pass
Pentachlorophenol	0.04	ND	1	ug/L	Pass
2,4,5-TP	0.2	ND	50	ug/L	Pass
Dinoseb	0.2	ND	7	ug/L	Pass
Picloram	0.1	ND	500	ug/L	Pass
Bentazon	0.2	ND		ug/L	
DCPA Acid Metabolites	0.2	ND		ug/L	
Semivolatile Organic Compounds (Ref: EPA 525.2)					
Hexachlorocyclopentadiene	0.1	ND	50	ug/L	Pass
EPTC	0.5	ND		ug/L	
Dimethylphthalate	2	ND		ug/L	
2,6-Dinitrotoluene	0.5	ND		ug/L	
2,4 Dinitrotoluene	0.5	ND		ug/L	
Molinate	0.1	ND		ug/L	
Diethylphthalate	2	ND		ug/L	
Propachlor	0.1	ND		ug/L	
Hexachlorobenzene	0.1	ND	1	ug/L	Pass
Simazine	0.07	ND	4	ug/L	Pass
Atrazine	0.1	ND	3	ug/L	Pass
Lindane	0.02	ND	0.2	ug/L	Pass
Terbacil	0.5	ND		ug/L	
Metribuzin	0.1	ND		ug/L	
Alachlor	0.1	ND	2	ug/L	Pass
Heptachlor	0.04	ND	0.4	ug/L	Pass
Di-n-butylphthalate	2	ND		ug/L	
Metolachlor	0.1	ND		ug/L	
Aldrin	0.1	ND		ug/L	
Heptachlor Epoxide	0.02	ND	0.2	ug/L	Pass
Butachlor	0.2	ND		ug/L	
p,p'-DDE (4,4'-DDE)	0.5	ND		ug/L	
Dieldrin	0.5	ND		ug/L	
Endrin	0.1	ND	2	ug/L	Pass
Butylbenzylphthalate	2	ND		ug/L	
bis(2-Ethylhexyl)adipate	0.6	ND	400	ug/L	Pass
Methoxychlor	0.1	ND	40	ug/L	Pass
bis(2-Ethylhexyl)phthalate (DEHP)	0.6	ND	6	ug/L	Pass
Benzo(a)Pyrene	0.02	ND	0.2	ug/L	Pass
Volatiles: EDB and DBCP (Ref: EPA 504.1)					
Ethylene Dibromide (EDB)	0.01	ND	0.05	ug/L	Pass
1,2-Dibromo-3-Chloropropane (DBCP)	0.01	ND	0.2	ug/L	Pass
Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)					
Dichlorodifluoromethane	0.5	ND		ug/L	
Chloromethane	0.5	ND		ug/L	
Vinyl Chloride	0.5	ND	2	ug/L	Pass



Sample Id: S-0001418632

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
<b>Organic Chemicals</b>					
Bromomethane	0.5	ND		ug/L	
Chloroethane	0.5	ND		ug/L	
Trichlorofluoromethane	0.5	ND		ug/L	
Trichlorotrifluoroethane	0.5	ND		ug/L	
Methylene Chloride	0.5	ND	5	ug/L	Pass
1,1-Dichloroethylene	0.5	ND	7	ug/L	Pass
trans-1,2-Dichloroethylene	0.5	ND	100	ug/L	Pass
1,1-Dichloroethane	0.5	ND		ug/L	
2,2-Dichloropropane	0.5	ND		ug/L	
cis-1,2-Dichloroethylene	0.5	ND	70	ug/L	Pass
Chloroform	0.5	4.2		ug/L	
Bromochloromethane	0.5	ND		ug/L	
1,1,1-Trichloroethane	0.5	ND	200	ug/L	Pass
1,1-Dichloropropene	0.5	ND		ug/L	
Carbon Tetrachloride	0.5	ND	5	ug/L	Pass
1,2-Dichloroethane	0.5	ND	5	ug/L	Pass
Trichloroethylene	0.5	ND	5	ug/L	Pass
1,2-Dichloropropane	0.5	ND	5	ug/L	Pass
Bromodichloromethane	0.5	3.2		ug/L	
Dibromomethane	0.5	ND		ug/L	
cis-1,3-Dichloropropene	0.5	ND		ug/L	
trans-1,3-Dichloropropene	0.5	ND		ug/L	
1,1,2-Trichloroethane	0.5	ND	5	ug/L	Pass
1,3-Dichloropropane	0.5	ND		ug/L	
Tetrachloroethylene	0.5	ND	5	ug/L	Pass
Chlorodibromomethane	0.5	1.4		ug/L	
Chlorobenzene	0.5	ND	100	ug/L	Pass
1,1,1,2-Tetrachloroethane	0.5	ND		ug/L	
Bromoform	0.5	ND		ug/L	
1,1,2,2-Tetrachloroethane	0.5	ND		ug/L	
1,2,3-Trichloropropane	0.5	ND		ug/L	
1,3-Dichlorobenzene	0.5	ND		ug/L	
1,4-Dichlorobenzene	0.5	ND	75	ug/L	Pass
1,2-Dichlorobenzene	0.5	ND	600	ug/L	Pass
Methyl-tert-Butyl Ether (MTBE)	0.5	ND		ug/L	
Methyl Ethyl Ketone	5	ND		ug/L	
Toluene	0.5	ND	1000	ug/L	Pass
Ethyl Benzene	0.5	ND	700	ug/L	Pass
m+p-Xylenes	1	ND		ug/L	
o-Xylene	0.5	ND		ug/L	
Styrene	0.5	ND	100	ug/L	Pass
Isopropylbenzene (Cumene)	0.5	ND		ug/L	
n-Propylbenzene	0.5	ND		ug/L	
Bromobenzene	0.5	ND		ug/L	
2-Chlorotoluene	0.5	ND		ug/L	
4-Chlorotoluene	0.5	ND		ug/L	
1,3,5-Trimethylbenzene	0.5	ND		ug/L	
tert-Butylbenzene	0.5	ND		ug/L	
1,2,4-Trimethylbenzene	0.5	ND		ug/L	

Sample Id: **S-0001418632**

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
<b>Organic Chemicals</b>					
sec-Butylbenzene	0.5	ND		ug/L	
p-Isopropyltoluene (Cymene)	0.5	ND		ug/L	
1,2,3-Trimethylbenzene	0.5	ND		ug/L	
n-Butylbenzene	0.5	ND		ug/L	
1,2,4-Trichlorobenzene	0.5	ND	70	ug/L	Pass
Hexachlorobutadiene	0.5	ND		ug/L	
1,2,3-Trichlorobenzene	0.5	ND		ug/L	
Naphthalene	0.5	ND		ug/L	
Benzene	0.5	ND	5	ug/L	Pass
Total Trihalomethanes	0.5	8.7	80	ug/L	Pass
Total Xylenes	0.5	ND	10000	ug/L	Pass
<b>Chlorinated Pesticides and Organohalides by EPA 508.1</b>					
Toxaphene	0.1	ND	3	ug/L	Pass
Chlordane	0.1	ND	2	ug/L	Pass
PCB 1016	0.08	ND	0.5	ug/L	Pass
PCB 1221	0.1	ND	0.5	ug/L	Pass
PCB 1232	0.1	ND	0.5	ug/L	Pass
PCB 1242	0.1	ND	0.5	ug/L	Pass
PCB 1248	0.1	ND	0.5	ug/L	Pass
PCB 1254	0.1	ND	0.5	ug/L	Pass
PCB 1260	0.1	ND	0.5	ug/L	Pass
Endrin	0.01	ND	2	ug/L	Pass
Total PCBs	0.1	ND	0.5	ug/L	Pass



<<Additional Information>>

Sample Id: S-0001418632

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
<b>Physical Quality</b>			
Alkalinity (Ref: SM 2320-B)	20-SEP-2017		
Color (Ref: SM 2120-B)	20-SEP-2017	10:10	
Specific Conductance (Ref: EPA 120.1)	20-SEP-2017		
Corrosivity (Ref: SM 2330-B)			
Hardness, Total (Ref: EPA 200.7)			
Solids, Total Dissolved (Ref: SM 2540-C)	20-SEP-2017		
Turbidity (Ref: EPA 180.1)	20-SEP-2017	10:25:00	
pH (Ref: SM4500-HB)	20-SEP-2017	08:57:30	
Bicarbonate (Ref: SM 2320-B)			
Odor, Threshold Number ( Ref. Standard Methods 2150 B)	20-SEP-2017		
<b>Microbiological Quality</b>			
Coliforms and E. coli (Ref: SM 9223)	21-SEP-2017	12:42	20-SEP-2017 12:33
<b>Disinfection Residuals/Disinfection By-Products</b>			
Bromate (Ref: EPA 300.1)	20-SEP-2017		
Chloramines (Ref: SM 4500-Cl-G)	20-SEP-2017	12:29:00	
Chlorite (Ref: EPA 300.1)	20-SEP-2017		
Chlorine Dioxide (Ref: SM 4500-ClO2-D)	20-SEP-2017	12:29:00	
Haloacetic Acids (Ref: EPA 552.2)	3-OCT-2017		2-OCT-2017
Chlorine, Total Residual (ref. SM 4500CL-G)	20-SEP-2017	12:29:00	
<b>Radiologicals</b>			
Uranium in Drinking Water by ICPMS (Ref: EPA 200.8)	26-SEP-2017		
Gross Alpha and Beta Radioactivity in Drinking Water (Ref: EPA 900.0)	25-SEP-2017		
Total Radium-226, Radium-228 Combined Activity (SM7500Ra-B & SM7500Ra-D)	4-OCT-2017		
<b>Inorganic Chemicals</b>			
Aluminum (Ref: EPA 200.8)	26-SEP-2017		
Antimony in Drinking Water by ICPMS (Ref: EPA 200.8)	26-SEP-2017		
Arsenic in Drinking Water by ICPMS (Ref: EPA 200.8)	26-SEP-2017		
Barium in Drinking Water by ICPMS (Ref: EPA 200.8)	26-SEP-2017		
Beryllium in Drinking Water by ICPMS (Ref: EPA 200.8)	26-SEP-2017		
Bromide (Ref: EPA 300.1)	20-SEP-2017		
Cadmium in Drinking Water by ICPMS (Ref: EPA 200.8)	26-SEP-2017		
Calcium in Drinking Water by ICPAES (Ref: EPA 200.7)	26-SEP-2017		
Chloride (Ref: EPA 300.0)	20-SEP-2017		
Chromium in Drinking Water by ICPMS (Ref: EPA 200.8)			



<<Additional Information>>

Sample Id: S-0001418632

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
<b>Inorganic Chemicals</b>			
	26-SEP-2017		
Copper in Drinking Water by ICPMS (Ref: EPA 200.8)	26-SEP-2017		
Cyanide, Total (Ref: EPA 335.4)	28-SEP-2017		
Fluoride (Ref: SM 4500-F-C)	21-SEP-2017		
Iron in Drinking Water by ICPAES (Ref: EPA 200.7)	26-SEP-2017		
Lead in Drinking Water by ICPMS (Ref: EPA 200.8)	26-SEP-2017		
Magnesium in Drinking Water by ICPAES (Ref: EPA 200.7)	26-SEP-2017		
Manganese in Drinking Water by ICPMS (Ref: EPA 200.8)	26-SEP-2017		
Mercury in Drinking Water by ICPMS (Ref: EPA 200.8)	26-SEP-2017		
Nickel in Drinking Water by ICPMS (Ref: EPA 200.8)	26-SEP-2017		
Nitrogen, Nitrate (Ref: EPA 300.0)	20-SEP-2017	14:19:47	
Nitrogen, Nitrite (Ref: EPA 300.0)	20-SEP-2017	14:19:47	
Total Nitrite + Nitrate-Nitrogen (Ref: EPA 300.0)			
Potassium by ICPAES (Ref: EPA 200.7)	26-SEP-2017		
Selenium in Drinking Water by ICPMS (Ref: EPA 200.8)	26-SEP-2017		
Silver in Drinking Water by ICPMS (Ref: EPA 200.8)	22-SEP-2017		
Sodium in Drinking Water by ICPAES (Ref: EPA 200.7)	26-SEP-2017		
Sulfate as SO4 (Ref: EPA 300.0)	20-SEP-2017		
Surfactants, Methylene Blue Active Substances (Ref: SM 5540-C)	20-SEP-2017	14:19:00	
Thallium in Drinking Water by ICPMS (Ref: EPA 200.8)	26-SEP-2017		
* Phenolics, Total Recoverable (Based on EPA 420.2)	20-SEP-2017		
Zinc in Drinking Water by ICPMS (Ref: EPA 200.8)	26-SEP-2017		
<b>Organic Chemicals</b>			
Diquat (Ref: EPA 549.2)	28-SEP-2017		26-SEP-2017
Endothall (Ref: EPA 548.1) - (ug/L)	21-SEP-2017		21-SEP-2017
Glyphosate (Ref: EPA 547)	20-SEP-2017		
2,3,7,8-TCDD (Ref: EPA 1613B)	29-SEP-2017		28-SEP-2017
Carbamate Pesticides (Ref: 531.2)	3-OCT-2017		
Herbicides (Ref: EPA 515.3)	6-OCT-2017		4-OCT-2017
Semivolatile Organic Compounds (Ref: EPA 525.2)	28-SEP-2017		28-SEP-2017
Volatiles: EDB and DBCP (Ref: EPA 504.1)	20-SEP-2017		
Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)	26-SEP-2017		
Chlorinated Pesticides and Organohalides by EPA 508.1	3-OCT-2017		





**Testing Laboratories:**

	<u>Flag</u>	<u>Id</u>	<u>Address</u>
All work performed at: (Unless otherwise specified)	→	NSF_AA	NSF International 789 N. Dixboro Road Ann Arbor MI 48105

**References to Testing Procedures:**

<u>NSF Reference</u>	<u>Parameter / Test Description</u>
C0842	Gross Alpha and Beta Radioactivity in Drinking Water (Ref: EPA 900.0)
C0980	Total Radium-226, Radium-228 Combined Activity (SM7500Ra-B & SM7500Ra-D)
C1188	Odor, Threshold Number ( Ref. Standard Methods 2150 B)
C2015	2,3,7,8-TCDD (Ref: EPA 1613B)
C3013	Chloride (Ref: EPA 300.0)
C3014	Bromide (Ref: EPA 300.1)
C3015	Bromate (Ref: EPA 300.1)
C3016	Nitrogen, Nitrate (Ref: EPA 300.0)
C3017	Nitrogen, Nitrite (Ref: EPA 300.0)
C3018	Sulfate as SO4 (Ref: EPA 300.0)
C3019	Cyanide, Total (Ref: EPA 335.4)
C3021	* Phenolics, Total Recoverable (Based on EPA 420.2)
C3025	Chlorite (Ref: EPA 300.1)
C3033	Aluminum (Ref: EPA 200.8)
C3036	Arsenic in Drinking Water by ICPMS (Ref: EPA 200.8)
C3039	Barium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3042	Beryllium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3044	Calcium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3047	Cadmium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3053	Chromium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3059	Copper in Drinking Water by ICPMS (Ref: EPA 200.8)
C3064	Iron in Drinking Water by ICPAES (Ref: EPA 200.7)
C3072	Mercury in Drinking Water by ICPMS (Ref: EPA 200.8)
C3079	Potassium by ICPAES (Ref: EPA 200.7)
C3085	Magnesium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3086	Manganese in Drinking Water by ICPMS (Ref: EPA 200.8)
C3091	Sodium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3094	Nickel in Drinking Water by ICPMS (Ref: EPA 200.8)
C3101	Lead in Drinking Water by ICPMS (Ref: EPA 200.8)
C3114	Antimony in Drinking Water by ICPMS (Ref: EPA 200.8)
C3116	Selenium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3128	Thallium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3136	Zinc in Drinking Water by ICPMS (Ref: EPA 200.8)
C3144	Solids, Total Dissolved (Ref: SM 2540-C)
C3145	Turbidity (Ref: EPA 180.1)
C3155	Surfactants, Methylene Blue Active Substances (Ref: SM 5540-C)
C3157	Color (Ref: SM 2120-B)
C3158	Specific Conductance (Ref: EPA 120.1)
C3159	pH (Ref: SM4500-HB)
C3161	Hardness, Total (Ref: EPA 200.7)
C3166	Bicarbonate (Ref: SM 2320-B)
C3168	Chlorine Dioxide (Ref: SM 4500-ClO2-D)
C3169	Chloramines (Ref: SM 4500-Cl-G)
C3170	Fluoride (Ref: SM 4500-F-C)
C3174	Alkalinity (Ref: SM 2320-B)
C3188	Silver in Drinking Water by ICPMS (Ref: EPA 200.8)



**References to Testing Procedures: ( Cont'd )**

<b>NSF Reference</b>	<b>Parameter / Test Description</b>
C3210	Corrosivity (Ref: SM 2330-B)
C3342	Total Nitrite + Nitrate-Nitrogen (Ref: EPA 300.0)
C3393	Chlorine, Total Residual (ref. SM 4500CL-G)
C4076	Carbamate Pesticides (Ref: 531.2)
C4145	Diquat (Ref: EPA 549.2)
C4154	Endothall (Ref. EPA 548.1) - (ug/L)
C4193	Glyphosate (Ref: EPA 547)
C4198	Haloacetic Acids (Ref: EPA 552.2)
C4202	Herbicides (Ref: EPA 515.3)
C4343	Semivolatile Organic Compounds (Ref: EPA 525.2)
C4411	Volatiles: EDB and DBCP (Ref: EPA 504.1)
C4496	Uranium in Drinking Water by ICPMS (Ref: EPA 200.8)
C4661	Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)
C4669	Chlorinated Pesticides and Organohalides by EPA 508.1
M0115	Coliforms and E. coli (Ref: SM 9223)

**Certifications:**

Arizona ( # AZ0655 )	California ( # 03214 CA )	Connecticut ( # PH-0625 )
Florida ( # E-87752 FL )	Hawaii	Indiana
Maryland ( # 201 )	Michigan ( # 0048 )	North Carolina ( # 26701 )
New Jersey ( # MI770 )	Nevada ( # MI000302010A )	New York ( # 11206 )
Pennsylvania ( # 68-00312 )	South Carolina ( # 81005 )	Virginia ( # 00045 )
Vermont ( # VT 11206 )		

Test descriptions preceded by an asterisk "\*" indicate that testing has been performed per NSF International requirements but is not within its scope of accreditation.

The reported result for Odor, Phenolics, Potassium, Specific Conductance, Radon and Total Residual Chlorine cannot be used for compliance purposes within the State of Arizona.

The reported results for Asbestos, Phenolics, pH, Chlorine Dioxide, Chloramines and Total Residual Chlorine are not covered by New York State certification.

**Notes:**

- 1) Bottled water sold in the United States shall not contain Fluoride in excess of the levels published by the USFDA in 21 CFR Part 165.110. These levels are based on the annual average of maximum daily air temperatures at the location where the bottled water is sold at retail. Please refer to the most current edition of the regulation to determine the Fluoride maximum level that pertains to your product.
- 2) A blank on the FDA SOQ column indicates that no maximum level has been established by the FDA for that contaminant.
- 3) An ND result means that the contaminant was not detected at or above the reporting limit.

For a list of NSF International Method Detection Limits refer to [http://www.nsf.org/media/enevs/documents/minimum\\_detection\\_level\\_spreadsheet.pdf](http://www.nsf.org/media/enevs/documents/minimum_detection_level_spreadsheet.pdf).